

# VOC Content Test Certificate

Monday May 17<sup>th</sup>, 2010

Supplier: Novatex Products Pty Ltd (5/26 Newton Road Wetherill Park NSW 2164)

Sample Description: Novaflex Plus non-slump premium grade ceramic tile adhesive.

Date Tested: May 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Novaflex Plus</b>
Ceramic Tile Adhesive 65grams per Litre as VOC content material	<b>4grams per Litre as VOC content material</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Novaflex Plus</b>
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	<b>4 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F100504**