

VOC Content Test Certificate

Monday May 17th, 2010

Supplier: Novatex Products Pty Ltd (5/26 Newton Road Wetherill Park NSW 2164)

Sample Description: Supanova super grade ceramic tile adhesive

Date Tested: May 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Supanova
Ceramic Tile Adhesive 65grams per Litre as VOC content material	3grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Supanova
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	3 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F100504